

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. _____ Dated: _____
It is certified that an inspection team headed by JE Phoola Singh
(Name of Officers with designation) from Dept. Water Supply & PHED Sanitation
inspected the The Asian School, Ludhiana
(Name & Address of the school) on 27/04/2026 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. DWTL/2627/00020 dated 30/04/2026
of _____ (PHED Lab) certified that
the The Asian School, LDH (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 31/03/2027.

Signature with Seal: [Signature]
Name: Sub Divisional Engineer
Designation: Water Supply & Sanitation
Name & Address of the Office / Department: Sub Div. No. 1, Ludhiana.
Sub. Divisional Engineer
Dept. of Water Supply & Sanitation.

To The Asian School
Near PCIE Collage, Baddawal
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

[Signature]
President

[Signature]
PRINCIPAL
THE ASIAN SCHOOL
LUDHIANA

DISTRICT WATER TESTING LABORATORY, LUDHIANA

Water Supply & Sanitation Division no.1, Court Complex, Ludhiana

dwtlabludhiana@gmail.com

To,

S.D.E. , Sub Div. No. - 1
DWSS , Ludhiana


No.: DWTL/2627/00020 Dated : 30/04/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 367 Dated: 27/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 3 Water sample/s received on dated 28/04/2026. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Ludhiana

D/A : Test Report



Authorized Signatory
For, District water Testing Laboratory
Ludhiana

For Shree Shyam Educational Society



President



PRINCIPAL

THE ASIAN SCHOOL
LUDHIANA

DISTRICT WATER TESTING LABORATORY, LUDHIANA
Water Supply & Sanitation Division no.1, Court Complex, Ludhiana

dwtlabludhiana@gmail.com



TC-13223

TEST REPORT			
Name & Address of Customer : S.D.E. , Sub Div. No. - 1 DWSS , Ludhiana		Customer Reference No.	No : 367 Dated : 27/04/2026
		Sample Submitted by	S.D.E.
		Date of Sample Receipt	28/04/2026
		Analysis Starting Date	28/04/2026
		Analysis completion Date	30/04/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC132232600000042F	Sample Type :	Water
Test Report No.:	DWTL/2627/00020	Date of Issue :	30/04/2026
Registration no.:	DWTL/REG2627/00134	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Transparent Glass Bottle
Scheme/Source:	Baddowal(TUBEWELL)	Location/Depth :	Asian School Baddowal (Submersible) / NA
Village :	BADDOWAL	Habitation :	BADDOWAL
Block:	Sadhar	District :	Ludhiana
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.64	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	378	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	300	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	272	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	74	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	21	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	30	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Brij Bhushan

Sh, Brij Bhushan
Quality Manager
Authorized Signatory
For, District water Testing Laboratory
Ludhiana

End of the Test Report

For Shree Shyam Sharma

President

Neha Singh
PRINCIPAL
THE ASIAN SCHOOL
LUDHIANA

Page No : 1/3

DISTRICT WATER TESTING LABORATORY, LUDHIANA

Water Supply & Sanitation Division no.1, Court Complex, Ludhiana

dwtbludhiana@gmail.com



TC-13223

TEST REPORT

Name & Address of Customer : S.D.E. , Sub Div. No. - 1 DWSS , Ludhiana		Customer Reference No. No : 367 Dated : 27/04/2026
		Sample Submitted by S.D.E.
		Date of Sample Receipt 28/04/2026
		Analysis Starting Date 28/04/2026
		Analysis completion Date 30/04/2026
Discipline : Chemical Testing		Group: Water
ULR No.:	TC132232600000042F	Sample Type : Treated Water
Test Report No.:	DWTL/2627/00020	Date of Issue : 30/04/2026
Registration no.:	DWTL/REG2627/00135	Condition of Sample : Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle: 1000 ml / Transparent Glass Bottle
Scheme/Source:	Baddowal(TUBEWELL)	Location/Depth : Asian School Baddowal (R.O. Sample - 1) / NA
Village :	Not Mentioned	Habitation : Not Mentioned
Block:	Sadhar	District : Ludhiana
Latitude :	Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.10	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable*	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	372	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	296	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	272	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	72	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	22	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	30	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Brij Bhushan

Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, District water Testing Laboratory
Ludhiana

End of the Test Report

[Signature]
President

PRINCIPAL
[Signature]
THE ASIAN SCHOOL
LUDHIANA

DISTRICT WATER TESTING LABORATORY, LUDHIANA

Water Supply & Sanitation Division no.1, Court Complex, Ludhiana

dwtbludhiana@gmail.com



TC-13223

TEST REPORT

Name & Address of Customer : S.D.E. , Sub Div. No. - 1 DWSS , Ludhiana		Customer Reference No. No : 367 Dated : 27/04/2026
		Sample Submitted by S.D.E.
		Date of Sample Receipt 28/04/2026
		Analysis Starting Date 28/04/2026
		Analysis completion Date 30/04/2026
Discipline : Chemical Testing		Group: Water
ULR No.:	TC13223260000042F	Sample Type : Treated Water
Test Report No.:	DWTLL/2627/00020	Date of Issue : 30/04/2026
Registration no.:	DWTLL/REG2627/00136	Condition of Sample : Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle: 1000 ml / Transparent Glass Bottle
Scheme/Source:	Baddowal(TUBEWELL)	Location/Depth : Asian School Baddowal (R.O. Sample - 2) / NA
Village :	Not Mentioned	Habitation : Not Mentioned
Block:	Sadhar	District : Ludhiana
Latitude :	Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.47	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	41	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	20	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	BDL	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	BDL	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	BDL	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	16	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

For Shree Shyam Bhasin - President

President

Reviewed and Approved By

Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, District water Testing Laboratory
Ludhiana

End of the Test Report

PRINCIPAL
THE ASIAN SCHOOL
LUDHIANA